




# **RPC Operation and Plans**

#### Jan Eysermans On behalf of the CMS Muon group

CMS Run & DPG Coordination Workshop 24-26 January 2017, Torino, Cavallerizza Reale

#### **RPC Operation in 2016**





- Stable operation during 2016
- 99.97 % effectiveness
- Active fraction of detector channels between 97.9 – 98.3 %
  - plan to recover 0.5 1% of total chambers during EYETS
- Data quality of all runs up to last pp-run were marked as **GOOD** 
  - 5 runs marked as **BAD** corresponding to **145 pb**<sup>-1</sup>
  - Total downtime corresponding to 12.51 pb<sup>-1</sup>


First Runtime	Begin Time	Last Runtime	End Time	Runtime	No stable beam	Luminosity, pb <sup>-1</sup> pp		Eff. by Lumi (%)	lost,	Downtime Events, pb <sup>-1</sup> pp	Remaining Lumi loss, pb <sup>-1</sup> pp µb <sup>-1</sup> PbPb
HCFILL004726	2016.03.24 23:56:39	LHCFILL005451	2016.10.26 21:00:18	1805:36:21	0:00:00	40522.49	37323.35	92.11%	3199.14	12.51	3186.63

	Run time	Livetime	Downtime	Effectiveness	Events
Including non stable beam	1805:36:21	1805:00:28	0:35:53	99.97%	3
Stable beam only	1805:36:21	1805:00:28	0:35:53	99.97%	3


#### Downtime




- Total downtime of 35 minutes 53 seconds  $\rightarrow$  **12.51 pb**<sup>-1</sup>/**0.74%**
- Accumulated in 3 instances
- All caused by CCU errors:
  - crash of XDAQ in YEN-3 near (affecting both RE-3/RE-4 near)
  - RPC DAQ configuration halted  $\rightarrow$  run cannot be started
- Temporary fix in source code preventing crash XDAQ
  - root cause problem to be evaluated on hardware control boards
- EYETS: replacement of all RE-3 near control boards



January 26, 2016






Jan Eysermans

### Bad data certification runs



- Major failure with 48V power supply problems in W-2 affecting 6 sectors
- In situ solution:
  - corresponding worker W-2 far disabled
  - global running was not affected
- Problem was solved during next interfill
  - cleaned all connectors in UXC with contact spray
  - problem never appeared again



# Minor system failures and gas operation



- Minor system failures:
  - CAEN bus communication errors (LV boards turned OFF) → problem didn't appeared anymore after cleaning connectors
  - MAO OFF / loss communication with branch controller
  - DCS blocked peer
  - ...

 $\rightarrow$  none of them affected data taking


- Gas operation
  - very stable gas operation, no downtime nor gas kill alarm
  - though several maintenance activities planned in EYETS

#### Ambient temperature



- Temperature carefully monitored in barrel and endcap
- Observed decrease in temperature of ~ 0.5 degC since April 2016
- Affecting efficiency of chambers
  - 0.5 degC corresponds to ~ 10V shift in working point
  - 10V change of WP corresponds to efficiency drop of ~ 0.2 %
- Decided to implement high voltage temperature correction, on top of existing P correction

 $\rightarrow$  HV(P) = HV(P, T)



### EYETS maintenance activities (1)



- During EYETS only W-2/W+2/RE+1/RE-1 accessible
- RPC Gas maintenance:
  - gas leak reparation in W-2 and W+2
  - 10 to be checked and try to repair
  - 5 leaks aimed to be repaired  $\rightarrow$  reduction of leak rate about 100 l/h
- Gas leak reduction by installing valves on return lines and flow cell adjustment → expected reduction of 50 l/h
- Total reduction of 150 l/h

### EYETS maintenance activities (2)

- Barrel threshold reparations:
  - Replacing failed distribution board for threshold control
- Endcap LV reparations
  - 6 chambers to be repaired
  - 2 already done (connector problems)
- 10 HV connector reparation of chambers now operating in single gap mode
- Control boards replacement in RE-3 to avoid further CCU errors + monitor CCU errors during commissioning



**"partially" extraction:** a special tool has been build for LS1 in order to "partially" extract the DT&RPC station for 80 cm ONLY in order to have access on the RPC Threshold control board.

We are using this tool almost during all long technical stop.



#### **EYETS** monitoring activities





- Annual resistivity scan with argon
- Gas leak measurements
- Cooling test at 12 bar to check the tightness of cooling pipes

#### RPC Inclusion in L1 muon trigger



- **OMTF:** combine RPC + DT + CSC hits
  - RPCs in OMTF since beginning of 2016
- **BMTF:** combine DT + RPC hits
  - TwinMux deployment near end of 2016
  - Successful tests performed in 2016 p-pb collisions
  - measured average increase of trigger efficiency by 1.3%
- EMTF: combine CSC + RPC hits to increase trigger efficiency in |η| < 1.85 and CSC ring gaps</li>
  - CPPF hardware boards ready + tests ongoing
  - EYETS: installation at P5 + tests + commissioning





Jan Eysermans

### Calibration and run activities



- MWGR1:
  - no participation (still argon flux for resistivity/gas leak measurements)
- MWGR2:
  - plan to participate, focus commissioning EMTF
  - full detector operational → global check of detector + check repaired chambers during EYETS
- Cruzet: participation
- CRAFT:
  - threshold calibration without beam
- 2017 run requests:
  - high voltage scan scan to check stability of working points
  - threshold/noise scan near end of the year (without beam)

#### Organization for 2017



- **DOC shifter** (twiki.cern.ch/twiki/bin/view/CMS/RPCDOCduties)
  - guarantee continuous detector operation
  - "on call", monitoring of the RPC system, attending daily run meetings + report
  - weekly report at the TC and DPG meetings
- **Data Manager** (twiki.cern.ch/twiki/bin/viewauth/CMS/RPCOfflineShifts\_Run2)
  - data certification at CMS centre, also offline CMS centres available now
  - certification based on several tools including noise tool, WBM, DQM
  - weekly report at the TC and DPG meetings
- **Prompt Feedback Monitoring** (twiki.cern.ch/twiki/bin/view/CMS/RPCPromptAnalysis)
  - aim to investigate detector performance on daily basis, guaranteeing good performance
  - extended use of DQM/WBM/Noise tools
  - close collaboration with DOC
  - weekly report at the DPG meetings + attendance of TC meeting

#### Summary




- Excellent operation of the RPCs in 2016 with minor problems or system failures
- EYETS maintenance activities ongoing including with focus on gas maintenance, HV/LV repairs and RPC inclusion in L1 muon trigger
- Plan to participate from MWGR2 and ongoing calibration runs

#### Backup

# EMTF algo with RPCs: v1

- Because of RPC+CPPF latency, won't use RPC hits for pattern-formation
  - Not a severe disadvantage only need CSC LCTs in 2 stations to fire pattern
- Assign RPC hit zone based on θ, match closest in φ to fired pattern
  - For now, only use RPC hit if no CSC LCT can be matched in that station
  - Widen dθ window to 2.3° (8 units)
- For pT assignment, set all dθ values with RPCs to 0, CLCTs to straightest



#### **Andrew Brinkerhoff**

# **CPPF** concentrator

- CPPF will concentrate RPC links, cluster fired strips, and assign θ and φ coordinates on the EMTF scale
  - Each link will carry up to 2 hits from each of 6 subsectors: ring 2 in stations 1 and 2, rings 2 and 3 in stations 3 and 4
  - Total of 6 CPPF-EMTF links per sector (+1 from the neighbor sector)
  - All contiguous strips in a single station/subsector/ring/roll clustered into a single hit, with φ defined by central strip or half-strip
  - φ in units of 1/15° (vs. 1/60° from CSCs), θ units of 36.5/32° (vs. 36.5/128 from CSCs)

