






Ecogas - Weekly shift report


Mapse Barroso Ferreira Filho

Eco-gas meeting - 03/03/2021

Report: 26/Feb

- System at stability run.
- Dew point at ~ 5.5 °C
- The HFO used liters was found in orange color. The value was 2.30 kL







Report: 27/Feb


 Dew point was ~5 °C -> adjusted the dry mixture to 18.5 l/h and the value has been restored to more or less 4 °C

Report: 28/Feb

• Gas flow reducing since ~ 10 pm (27/Feb) -> HFO 2.47 k used Liters









Report: 01/March

- We replaced the HFO gas bottle (Thanks to Demetrio!)
- We calibrated the bottle valve next to the valve with 1.5 mb.
- See <u>elog</u>.
- Dry gas mixture was adjusted to 18.20 L/h (60.7 %) Dew point ~ 4° C







Report: 02/March


- Source off for maintenance
- We did a High Voltage (HV) scan with the usual chambers: CMS-GT-2-0, CMS-KODEL_1-4 and EPDT.
- HV scan:
 - ID: 142
 - Source OFF
 - 4 °C Dew point gas mixture
 - Waiting time (min): 1
 - Measuring time (min): 1
 - HV points: 22
 - Mixture: ECOGAS2
- For some reason *logger* was down. I restarted it and then adjusted the DRY flow to 17 L/h in order to reach 4°C for dew point.

Report: 03/March

• Dew point was found ~ 3.45 C

HVet (V)

- Grafana without data: For some reason logger was down again.
- HV scan results:



Conclusions

- System seems behaving well
- Major issue was the HFO over. Other than this I did dew point regulations and the reset of logger on Ecogas laptop
- Thank you Gianluca for the support