



# Coil power supplies in DTT

A. Lampasi

*DTT S. c. a r. l.*

Industrial Opportunity Days 2022

Osservatorio Astronomico di Capodimonte (Napoli)

9 June 2022


---

*DTT Consortium (DTT S. c. a r. l.) – Via E. Fermi, 45, 00044 Frascati (Roma), Italy*





- Coil PSs (high-current PSs)
  - Not included in this presentations:
    - H&CD (high voltage)
    - STATCOM
- Two categories, related to respective coil procurements
  - Superconducting coils
  - Copper (in-vessel coils)



Less urgent, but now PNRR


# Overview of main high-current PSs



*Update in progress*

- 1 Toroidal Field (TF) PS
- 6 Poloidal Field (PF) PSs
- 6 Central Solenoid (CS) PSs
- 2 Vertical Stabilization (VS) PSs
- 3-4 Divertor (DIV) PSs
- 27 Non-Axisymmetric (NA) PSs
- Other minor PSs

# Presented subsystems & partners



# PSs: General Status



- Budget
- Schedule
- Performances
- Layout

Compliant with expectations

It is not obvious:

- Raw material increase
- Russian components

- Resources
- Inputs/Interfaces


Not in line with expectations

# Problem of Cold Test Facility (CTF)




In Frascati

Ready in  $\approx 1$  year



# DTT superconducting coils




- TF, PF and CS PSs have very different characteristics
  - $\approx 100/3600$  s/s vs. Steady state
- Different PSs also in CTF

# TF PS: 2 Procurements: TF PS + FDUs



Discharge $\tau$	5 s
Peak voltage	$\approx 5.5$ kV



Operations	Continuous
Quadrants	2
Operating current	42.5 kA
Voltage	100 V

Number of TFCs	18
Single coil inductance	48 mH
Total inductance	2.272 H

# TF PS technical issues




- 24-pulses thyristor bridge
- Contract signed on 08/03/22 with Jema (Spain)
- KoM held on 22/03/22
- Delivery in CTF foreseen at September '23
- Afterwards, new contract for installation in DTT
  
- No expected relevant criticalities
- Open items/procurement opportunities:
  - Transformers (secondary voltage)
  - Control interfaces CODAS
  - Dummy load
  - Local reactive and harmonic mitigation

# TF FDU technical issues





- Contract signed on 18/05/22 with OCEM (Italy)
- KoM held on 25/05/22
- Delivery of «mock-up» in CTF foreseen at November '23
- Delivery and installation in DTT in April '26
- Several novelties:
  - JT-60SA: 25.7 kA  $\rightarrow$  42.5 kA, <2.8 kV  $\rightarrow$  >5.5 kV
  - Varistors
- Relevant criticalities
  - Russian current transducer
  - Russian pyrobreakers  
Problem  $\rightarrow$  Opportunity  
Totally static switches: Faster (less energy in coils), safer?, better layout?
  - Cooling
  - Discharge time to be optimized according to magnet design


# Layout TF PS and FDU in Building 184



- Layout still with pyrobreakers
- DC busbars to be updated later




# PF PS Procurement Issues







Many modifications and updates in 21/22

- External Panels on scenarios and magnets
- Higher voltage, no SNU's, FDU's (in crowbar?)
- Discharge  $\tau$  still valid?




Global (PS e load)							
Quadrants (to load)		4	4	2	2	4	4
Load inductance	mH	454	298	690	690	298	454
Nominal current	kA	18.8	20.9	11.5	27.9	22.7	28.5
Max voltage on load	kV	2	3	3	3	3	2

# PF PS reference scenario (TBC)



# Basic (ideal) principle of storage/recovery



# Supercapacitors for PF and CS PSs



Working prototype: 2 kA, 10 s




Dimensions:  
120 x 60 x 190 cm  
= **1.4 m<sup>3</sup>**

Wheels to move it!

Connections: just the  
plug and the load




Previous system: 2 kA, 1 s



Total dimensions:  
**> 10 m<sup>3</sup> (> 7 times)**  
+ dedicated 20-kV line  
and 324-V line

Fixed installation  
with many connections

# Large(st) energy storage installation



- Total Energy Storage for 12 PSs: 600 MW, 3600 MJ, 960 kWh
- Moreover, ENEA has SMESs and flywheels
- Comparison:
  - Korea: 25 MW supercap in several facilities
  - Endesa STORE, Canary Islands, Spain supercap: 4 MW, 20 MJ
  - Terna, Sicilia + Sardegna supercap: 1+1 MW, 1+1 MJ
  - Terna has some battery systems in order of 10 MW
  - DTT could be an “electrostatic lake” (Italy has 4 hydro-storage lakes at 1 GW)



If you like to know more: [www.supercap.org](http://www.supercap.org)

# PF PS Procurement Status



- Call for Tenders in Autumn 2022
  - Delivery to FCCTF: 16 months? Test of PF6
  - Coordination with CS and FDU mock-up

# Central Solenoid (CS) PSs




6 independent PSs:

1. CS3U (upper)
2. CS2U
3. CS1U
4. CS1L (lower)
5. CS2L
6. CS3L

# CS PS reference scheme



*Update in progress*



# CS Procurement status





- All tender documents (including administrative) ready and approved in 2021, but frozen
  - External Panel and study ongoing
  - Higher current?
- Call for Tender in 2023
- Criticality:
  - Test of CS in FCCTF, maybe can be performed by PF PS

# IVS PS reference location and layout




ENEA Building 191 Floor -1  
(to be built)



# Vertical Stabilization (VS) PSs



*Update in progress*




- 2 independent PSs (VSU-VSL)
- Copper
- 4 quadrants


# Alternative topologies




Disruption is one of the main criteria for PS design! 6 times the nominal one!



Independently fed coils  
 → Sensitive to disruptions  
 → Require complex protections



Double coupled coils  
 → Problems in the available in-vessel space




Separate imbalance power supply



Presently selected solution

# Present specifications for VS PSs



VSA and VSB: 2 identical PSs:

- 4 quadrants
- IGBT-based
- Current = 4.4 kA
- Voltage = 2.0 kV


VIM PSs:

- 4 quadrants
- IGBT-based (maybe thyristors)
- Current = 6 kA
- Voltage = 2.5 kV
- Short operations (<1 s)
- High inductance and/or advanced protection


Turns might also be changed to optimize current and voltage at fixed power

High inductance assumed ( $L_{IM} \approx 100$  mH)


- Study to reduce
- Recycle FTU inductors



Reference scenario



# VSS open issues and future activities




Possible reduction of PSs: 3→2

But control more complicated:

- Conjunction of slow and fast control in the same PS
- HIL simulation

# VS PS layout (2 PSs, but with higher power)




# VS Procurement status



- Call for Tender could wait >2023
- Now PNRR: we should launch the Call for Tender early


# Divertor (DIV) PSs



*Update in progress*

- 4 independent PSs
- Copper
- 4 quadrants

# DIV: 2021 selected solution



Disruption is one of the main criteria  
for PS design



Separate imbalance branch


Maximum control speed: 4 Hz

- Thyristor converters  
(maybe, choice mainly  
based on costs)

Open issues and future  
activities:

- Possible update by other  
groups: 4 → 3 coils
- Turns to be optimized
- Inductance to be optimized
- Fast circuit breakers  
necessary for overcurrent?

# DIV PS layout (with good margin)




# DIV PS Procurement status



- Now PNRR
- For Call for Tender we could wait >2023

# Non-Axisymmetric (NA) PSs



- 27 independent
- Copper
- 4 quadrants


*Update in progress*

# NAS specifications and reference scheme




18 → 27 identical PSs:


- Single input power: 4 MW (TBC)
  - Output:
    - 4 quadrants
    - IGBT-based
  - Current  $\approx 2.5$  kA
    - DC  $\approx 2$  kA for  $\approx 100$  s
    - Sinusoidal  $\approx 500$  A for  $\approx 40$ -50 s
  - Voltage  $\approx 300$  V (good margin)
- Discussions to increase turns and/or current
    - kAt:  $\approx 30$  kAt  $\rightarrow >> 50$  kAt
  - Disruption analysis still preliminary



Design divided in 3 blocks  
of 9 DC/AC converters



# NAS layout




# NAS Procurement status



- Now PNRR
- For Call for Tender we could wait 2023

# DBS DC Busbars (or cables)




- Call for Tender >2023
- HTS busbars? PNRR

# Discussion on busbar penetrations




- Issues: neutrons, heat dissipation, electrical insulation, structural (seismic)
- Option: Increase dimensions at least in penetrations
- Final filling could be optimized and implemented later
- Contacts with other tokamaks

Backfill (typically concrete & reinforcement & coating or paint)



Infilling (expensive)



Modular panels of commercial material

# CSP Control System PSs



- Control System for PSS
- Activities are ongoing with CODAS
  - To define standard interfaces
  - To develop prototypes/demonstrators
  - Maybe integrate them in PROTO-SPHERA
- Hardware-in-the-loop (HIL)



## Other PS Components

- Several minor components
- When possible included in other procurements, as TF dummy load
- No criticalities

# Thank you for your attention!



For more info please contact:  
<https://www.dtt-project.it/>  
<http://www.afs.enea.it/lampasi>  
<http://www.supercap.org>  
[alessandro.lampasi@enea.it](mailto:alessandro.lampasi@enea.it)