

# TOF status: July and August summary

Sofia Strazzi, Manuel Colocci, Marco Giacalone




ALICE

**ALICE-ePIC meeting**  
August 28<sup>th</sup>, 2024  
Bologna



# June Technical Stop (TS1)

**Crate 35 back ON**  
Hardware intervention  
involving CAEN technicians  
→ LV cables replaced (June 11th)



We were forced to stay OFF from Tuesday night until Friday because the 18 kV harmonic filters (filtering glitches on the main electrical network) were disabled for maintenance.

- If filters are off, the switching-on of a power converter of a machine magnet near P2 can cause voltage drops (TOF is sensitive to this)
- This action is NOT allowed when filters are off, but taken in June, because of a misunderstanding. ALICE RC reported to the LPC coordinators to avoid the same "accident" in the future

**Crate 57 re-included** in readout → it didn't show problems for a couple of weeks, now removed, because not stable again

Other minor fixes

# Failure on HV CAEN Main Frame (July 8)

All **HV channels of alitofhv1 went down** around 5:30 PM (while running)



Access in CR4:

→ **Replacement of both power units** of main frame

Most likely the issue was on the 48V power converter i.e. CAEN A1532.

Reboot the OPC server of both alitofvn1 and alitofvn2 (TOF back ready to take data at around 7.15 PM)

# Replacement of alitofhv1 (July 15)

alitofhv1 going in «overtemp»

- **we were not able anymore to switch back ON any HV channel** (which stayed OFF) unless we rebooted the entire main frame
  - This happened twice

Access done:

- Problem solved by **replacing alitofvn1 (CAEN main frame)** (180→117)

**(In 2 months we had to substitute both HV CAEN mainframe)**

# Replacement of a CAEN LVPS (July 12)

**48 V of channel 02** (powering crates 70 and 71)  
going systematically in **Undervoltage** (it didn't manage to go above 24 V)

→ **LVPS CAEN** A3485A ("Maciste") on Rack I31 **replaced**

→ OK after the replacement

# Reboot of a mainframe (July 17)

**alitofoaelv1 (RackO32) not responding** (run 554316).

Access done:

→ Problem solved by **hardware reboot of the Mainframe** on the balconies

→ 1 Run (run 554323) without 1/4 of TOF links.

# Unclear event affecting several detectors (July 30)

<https://ali-bookkeeping.cern.ch/?page=log-detail&id=101714>.  
<https://ali-bookkeeping.cern.ch/?page=log-detail&id=101713>

- Run 554772, TOF suffered from a significant **drop in data rate**
- TOF **QC changed** significantly

Some  
more info

Two FEELIGHT objects (active channel map) for a single run. This occurred in the previous run, 554768.

The second map was loaded at (Sun Aug 25 09:59:26 CEST 2024), 2 minutes before the end of the run (10:01:22).

Run 544772 started at 10:10:30.



# Broken circuit breaker (August 20)

The **main circuit breaker in EXD107/25 was broken** → power cut  
→ **Loss of power supplies (1/4 of TOF)**

A few circuit breakers for 220V had to be **re-enabled manually** for TOF in racks I32-31-30

→ **After turning them back ON everything is fine**

2 fans not working

- Right fan of the top-notch filter on rack I32
- Central fan of the top-notch filter on rack I31


# External perturbations (August 26)

## The 18kV harmonic filter at P2 tripped off in the morning

Since that moment TOF experienced **many glitches**:

- (5:15) 10 crates went down (5V, 3.3V, and all LV off)
- (6:15) whole side A down (crates going in Unplugged)
- (6:42) some crates on both sides A and C

LHC switching off / ramping down their magnets (operating the related power converters at P2) in correlated times



After the glitches the crates were again reachable and we could turn them back again

«What we could propose is to include in the procedures for the CCC that ALICE is informed in case of a trip of the filter. In this case we can take preventive measures before LHC will operate their power converters.

At the same time we will try to implement an alert in DCS to warn the shift crew when the filter goes off.»

is there a state TOF could be brought to make it less sensitive to these perturbations? → TOF off?

# External perturbations (August 26)

The 18kV harmonic filter at P2 tripped off in the morning

Since that moment TOF experienced many glitches:

- (5:15) 10 crates went down (5V, 3.3V, and all LV off)
- (6:15) whole side A down (crates going in Unplugged)
- (6:42) some crates on both sides A and C



```
Every 1.0s: /SOFT/TEST/scancrate -c 0
ALICE - TOF Crate Test Facility on Crate # 0
Slot # 02 LTM Present (Got VME data 0x55555555)
Slot # 03 TRM/LTM/CPDM Absent (BERR detected)
Slot # 04 unknown (Got VME response 0xAAAA2AAA (Status:0))
Slot # 05 TRM/LTM/CPDM Absent (BERR detected)
Slot # 06 TRM Present (Got VME data 0xAAAAAAAA (FW: 0x7221 ACQ: 1)
Slot # 07 unknown (Got VME response 0xAAAA2AAA (Status:0))
Slot # 08 TRM Present (Got VME data 0xAAAAAAAA (FW: 0x7221 ACQ: 1)
Slot # 09 unknown (Got VME response 0xAAAA2AAA (Status:0))
Slot # 10 TRM Present (Got VME data 0xAAAAAAAA (FW: 0x7221 ACQ: 1)
Slot # 11 unknown (Got VME response 0xAAAA2AAA (Status:0))
Slot # 12 TRM/LTM/CPDM Absent (BERR detected)
```

**Crate 8:** cannot be powered on (August 26) LTM not going READY and 4 TRMs not responding at boot

To be investigated

We could turn them back again

ALICE is informed in case of a trip of the filter. In this case we can take preventive measures before LHC will operate their power converters. B.t.w., is there a state TOF could be brought to make it less sensitive to these perturbations? At the same time we will try to implement an alert in DCS to warn the shift crew when the filter goes off.»

# CURRENT SITUATION

**Crate 5:** All 2.7V channel  
(except those powering FEAC 1 and 2)  
in HVMAX (July 29)

**A1396 to be replaced**  
→ displacement of a TOF SM

**Crate 8:** LTM not going  
READY and 4 TRMs not  
responding at boot (August 26)

To be investigated

**Crates 22 and 23:** 48V in  
Undervoltage (July 22) → Maciste  
(CAEN LVPS) to be replaced  
→ Access will be asked next week  
(repaired spare returned at CERN)


The grid consists of 10 rows and 48 columns, with headers for pairs of crate numbers. Each cell contains either 'RE' (Ready) or 'OF' (Offline). Red arrows indicate specific issues:

- Row 1, Column 5 (05 04): 'OF' (pointed to by Crate 5 text)
- Row 1, Column 9 (09 08): 'OF' (pointed to by Crate 5 text)
- Row 1, Column 57 (57 56): 'OF' (pointed to by Crate 57 text)
- Row 5, Column 23 (23 22): 'OF' (pointed to by Crate 8 text)
- Row 5, Column 22 (23 22): 'OF' (pointed to by Crate 8 text)
- Row 1, Column 57 (57 56): 'OF' (pointed to by Crates 22 and 23 text)
- Row 1, Column 22 (23 22): 'OF' (pointed to by Crates 22 and 23 text)

01	00	05	04	09	08	13	12	17	16	21	20	25	24	29	28	33	32	37	36	41	40	45	44	49	48	53	52	57	56	61	60	65	64	69	68		
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	OF	OF	OF	RE	OF	RE	OF	RE	OF	RE	OF	OF	OF	RE	OF	OF	OF	RE	OF	RE	OF	RE	OF	RE	OF	RE	OF	OF	OF	OF	OF	RE	OF	RE	OF	RE	OF
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	OF	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE
RE	RE	OF	RE	RE	OF	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	RE	OF	RE	RE	RE	RE	RE	RE	RE	RE	RE

**Crate 57:**  
unstable DAQ

# Conclusions and plans (to be decided)



- ✓ 21<sup>st</sup> March: First SB @ injection
- ✓ 5<sup>th</sup> April: First SB @ full energy
- ✓ 19<sup>th</sup> April: Start of production (10 days in advance)
- ✓ 16<sup>th</sup> April: vdM scan
- ✓ 10<sup>th</sup> June: TS1

- ★ 21<sup>st</sup> October: TS2
- 24<sup>th</sup> October: Start of pp-ref
- 6<sup>th</sup> November: Start of Pb-Pb
- 25<sup>th</sup> November: Start of YETS

TS2

## Crate 8

- To be investigated **replacement of 2 Notch Filters** (fans not spinning in I31-32)

YETS

## Crate 57

- Some non conclusive tests done during last TS
- Stable for some time when switched on – we can try to reinclude it during Pb-Pb

## Crate 5

- Displacement of a SM needed

# Conclusions and plans (to be decided)

## Introduction of a fix related to the compressor (Francesco)

→ Protection to avoid a possible crash of the processes due to a pointer of the encoder

«Many processes crashing after throwing instance of 'boost::interprocess::lock\_exception'» <https://its.cern.ch/jira/browse/O2-5231>

## Scan in luminosity in pp

- Already analyzed
- Plot generated

## EOR failure

- Investigate why recently it is so frequently
- Implement a button for the shifter

OTHER  
(1) days in

TS2

## Crate 8

- To be investigated  
**replacement of 2 Notch Filters**  
(fans not spinning in I31-32)

YETS

## Crate 57

- Some non conclusive tests done during last TS
- Stable for some time when switched on – we can try to reinclude it during Pb-Pb

## Crate 5

- Displacement of a SM needed



BACKUP SLIDES

BACKUP SLIDES

# Notch Filters refurbishment

**26 Notch Filter** units (CAEN A3000NF) in TOF { filtering the three-phase input (400 V)  
supplying TOF 48 V power supplies (CAEN A3485A)

Dec & Jan: **all units were refurbished** in Viareggio ← { some capacitors reached the EOL (End Of Life)  
in ATLAS they caused start of fire twice

✓ Replacement of **capacitors at EOL**



CAEN reported that:

- ALICE-TOF: 50% capacitors intact (but degraded), 50% visibly deformed (heat)
- ATLAS (2-3xTOF power): 10% capacitors intact (but degraded), 90% visible deformed

✓ Replacement of **fans** and addition of **overheating protection**

**All units were re-installed** in the cavern (Jan 26<sup>th</sup>)

→ **operational** from Jan 27<sup>th</sup>







# TOF crates heat-exchangers unclogging




**11 TOF crates unclogged** using phosphoric acid (5-10% conc.) left to act for 1 or 2 days as in the previous YETS (Dec 2022-Feb 2023)

↳ TOF crates are water cooled → **obstruction** in the cooling plates, causing the water flow to stop, **causing overheating of the crate**



**Corrosion inhibitor injected in the cooling plant** to prevent the galvanic corrosion (Copper and Aluminium). Waiting analysis outcome of TS1 water samples.

# TRM replacement campaign



## TRMs disabled in 2023:

- 8 TRMs due to **instabilities**
- 4 TRMs to limit the **overheating**
  - **back ON after crates unclogg.** (+960 ch)
- Crates 31, 57 out of data taking
  - **crate 31 back** (+ 2160 ch)

## News in 2024:

- TRM 35-4 replaced (some ch disabled) (+219 ch)
- TRM 47-6-10-11 replaced → (+720 ch)
- TRM 47-9 replaced, but issues when HV ON

**+4059 ch back in readout ( ~ 2.7%)**

TOF MRPC map  
→ **stable since LS2**

- HV unipolar cables disconnected (broken connector on the sector side)
  - Partial inefficiency

