Report on weekly shift

Luca Quaglia


Ecogas weekly meeting

06/05/2025


Weekly report - 1

- Currently flushing with ECO2 and stability ongoing
- ABS 69 during the week and EP-DT RPC at full efficiency for ABS 69
- Few interruptions of isobutane flow during the week
 - Problem with an EV
 - Fixed now by replacing EV but better to keep an eye out
 - If isobutane goes below 0.4 → automatic gas kill of stability run
- Two source-off scans taken before the start of irradiation (on April 30th)
 - 1078 (here) → KODEL-H TOP > 100 uA, removed from next scan
 - 1079 (here)
- Three stability scans \rightarrow ATLAS and KODEL-H not included
 - 258 (stopped due to no isobutane, here)
 - 259 (stopped due to no isobutane, here)
 - 260 (ongoing, here)

Weekly report - 2










Weekly report - 3





























Instructions for next shifter

- Continue ongoing run (260) with EPDT at WP
 - At GIF++ weekly meeting (Thu) we will discuss whether we want to still have 69 or if we are satisfied
- If ABS 69 is maintained
 - EP-DT at WP (same config as run 260)
- If ABS 2.2 is put back
 - EP-DT at 10.6 kV

Chamber/gap	Enabled	Working voltage (V)	Standby voltage (V)	i0 (uA)	Attenuator standby
ALICE-2-1	V	10600	6500	50	1 (111) 🗸 🗸
EPDT-RPC25		11074	6500	300	1 (111) 🗸 🗸
SHiP-1-6		8800	5000	300	1 (111) 🗸 🗸
RE1_1_001-BOT		10600	6500	50	1 (111) 🗸 🗸
RE1_1_001-TN		10600	6500	50	1 (111) 🗸 🗸
RE1_1_001-TW		10600	6500	50	1 (111) 🗸 🗸